

Galena GILA Water Quality Report 2025

Public Water System ID #: AK2360159

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies. Last year, we conducted tests for over 80 contaminants. We only detected 12 of those contaminants, and found only 1 at a level higher than the EPA allows. As we informed you at the time, our water temporarily exceeded drinking water standards. (For more information see the section labeled Violations at the end of the report.)

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

The City of Galena's water supply is derived from groundwater near the facility. Water treatment consists of iron removal and hypo-chlorination for disinfection. Particulate removal is accomplished through pressure sand filtration. Water is softened using ion exchange.

Source water assessment and its availability

A source water assessment has been completed on one of the two wells. The wellhead received a susceptibility rating of Low and the aquifer received a susceptibility rating of High. Combining these two ratings produce a Low rating for the natural susceptibility of the well. For more information regarding the source water assessment or to receive a full copy of the report please contact ADEC at 907-269-7549. Information on your water source can be found at the ADEC Drinking Water Watch website: <https://dec.alaska.gov/DWW/>

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity: microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

If you have questions about your system, contact the Galena City office.

Monitoring and reporting of compliance data violations

1. We are required to sample monthly for Total Coliform; however, we did not sample in January, March, June, July, or October 2025. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. We returned to compliance with the submission of the February, April, August, and November TCR samples, respectively. The health effects of this violation are unknown.
2. We are required to report the level of chlorine found in the water in the distribution system when we perform our monthly total coliform sampling. We did not do this in January, March, June, July, or October 2025. Chlorine is a water additive used to control microbes. Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes, nose, and/or stomach discomfort. However, untreated water may contain organisms, including bacteria, viruses, and parasites, that can cause symptoms such as nausea, cramps, diarrhea and headaches. We returned to compliance with the submission of the February, April, August, and November TCR samples, respectively. The health effects of this violation are unknown.

Significant Deficiencies

Two significant deficiencies are outstanding from the 2024 Sanitary Survey:

1. There is not a backflow prevention device installed on the water supply line for the fire truck fill point. The fire truck fill point must be designed with a backflow prevention device to help prevent the risk of contamination of the potable water supply.
2. The backflow preventers are not being tested annually. The Uniform Plumbing Code requires all backflow prevention assemblies to be tested at the time of installation, repair, or relocation, and annually thereafter by a certified tester. A routine maintenance and testing schedule would help to increase the likelihood the backflow preventers are tested on a regular basis and addressed if issues are identified.

Additional Information for Lead

The system inventory does not include lead service lines.

We reviewed available historical service line information and information provided by customers that showed there were not lead, galvanized requiring replacement or unknown service lines in our PWS. You can obtain information about the results of the Lead Service Line Inventory by contacting the Galena City Office or at the following link: <https://ak-lsli-adec.hub.arcgis.com/>

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. GALENA WTP2 – GILA SYSTEM is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact GALENA WTP2 – GILA SYSTEM (Public Watersystem Id: AK2360159) by calling 907-656-1301. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Additional Information for Arsenic

Your drinking water meets EPA's standard for arsenic, and it does not contain levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report.

Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source	
				Low	High				
Disinfectants & Disinfection By-Products									
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)									
Chlorine (as Cl ₂) (ppm)	4	4	.19	0	.19	2024	No	Water additive used to control microbes	
Haloacetic Acids (HAA5) (ppb)	NA	60	3.9	NA	NA	2024	No	By-product of drinking water chlorination	
TTHMs [Total Trihalomethanes] (ppb)	NA	80	1.1	NA	NA	2024	No	By-product of drinking water disinfection	
Contaminants	MCLG	AL	Your Water	Range		Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source
				Low	High				
Inorganic Contaminants									
Copper - action level at consumer taps (ppm)	1.3	1.3	0.255	0.09	0.28	2025	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead - action level at consumer taps (ppb)	0	15	2.5	0.0	3.3	2025	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Violations and Exceedances									

Undetected Contaminants

The following contaminants were monitored for, but not detected, in your water.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Violation	Typical Source
Inorganic Contaminants					
Arsenic (ppb)	0	10	ND	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Nitrate [measured as Nitrogen] (ppm)	10	10	ND	No	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variations and Exemptions	Variations and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Contact Name: Shanda Huntington Phone: 907-656-1301